

NEBRASKA ADMINISTRATIVE CODE

Title 153 – State Fire Marshal

Chapter 1 – Nebraska State Fire Code Regulations

Section - .061. NFPA 58 “Liquefied Petroleum Gas Code” 2001 Ed.

Subsection: 3.2.18 - Internal Valves Date Change

Subsection: 3.4.9.2 - Repeal on the Prohibition on Gas Grills on Apartment Balconies (July 2006)

[1] **Subsection 3.2.18.1** Internal valves must be installed in the liquid and vapor openings of a container over 4000 gal (15.1 m³) that is installed after July 1, 2005. Similar protection is also required for **existing** containers over 4000 gal (15.1 m³) after **July 1, 2011**. Refer to 2.3.3.2(b) for the equipment requirements.

3.2.18.2 Automatic shutdown of internal valves in liquid service shall be provided using thermal (fire) actuation. The thermal element shall be within 5 ft (1.5 m) of the internal valve.

3.2.18.3 At least one remote shutdown station for internal valves in liquid service shall be installed not less than 25 ft (7.6 m) or more than 100 ft (30 m) from the liquid transfer point.

3.2.18.4 Emergency remote shutdown stations shall be identified by a sign incorporating the words “Propane — Container Liquid Valve Emergency Shutoff” in block letters of not less than 2 in. (51 mm) in height on a background of contrasting colors to the letters. The sign shall be visible from the point of transfer.

[2] **Subsection 3.4.9.2: Repeal** the prohibition of L.P. gas grills on apartment balconies.