NEBRASKA ADMINISTRATIVE CODE

TITLE 229 - DEPARTMENT OF LABOR

CHAPTER 3 - NOTICE OF INSTALLATION OF BOILERS AND PRESSURE VESSELS

001. This chapter is adopted pursuant to *Neb. Rev. Stat.* '48-727.

002. Owners, users and lessees of all jurisdictional boilers and ~~unfired~~ pressure vessels now in use or installed ready for use in the state of Nebraska, shall report to the Commissioner, giving the location, type, capacity, age, and date of installation of the boiler or ~~unfired~~ pressure vessel. Such boilers and ~~unfired~~ pressure vessels must be designed per applicable ASME codes, or have equivalent safety consistent with codes recognized in *Neb. Rev. Stat.* '48-727 of the Boiler Inspection Act to obtain an inspection certificate.

003. At least ten days prior to the installation of any jurisdictional boiler or ~~unfired~~ pressure vessel, the contractor, person, or entity installing the boiler or ~~unfired~~ pressure vessel shall give notice of the proposed installation to the Commissioner on a form prescribed by the Commissioner. The notice shall designate the proposed place and date of installation, the type and capacity of the boiler or pressure vessel, the use to be made of the boiler or ~~unfired~~ pressure vessel, the name of the company which manufactured the boiler or ~~unfired~~ pressure vessel, ~~and~~ whether the boiler or ~~unfired~~ pressure vessel is new or used<u>, and, if applicable, whether the inspection will be performed by a special inspector employed by an insurance company and commissioned pursuant to 229 NAC 11</u>. Any inspection of a new installation for which notice was not given to the Commissioner in accordance with this chapter and *Neb. Rev. Stat.* '48-730 shall be deemed a special inspection under 229 NAC 7, '005(A)(2); except that if the installation was done as a part of a repair process and written notice was given to the Commissioner prior to actual installation, the inspection shall not be considered a special inspection under 229 NAC 7, '005(A)(2).

004. All new installations of boilers, water heaters or pressure vessels shall be inspected by the state chief boiler inspector<u>,</u> ~~or~~ a deputy state boiler inspector<u>, or a special inspector employed by an insurance company and commissioned pursuant to 229 NAC 11</u> prior to operation of the unit.

005. If an owner or user enters into a contract with an installer and in that contract the installer is responsible for all inspection, permit or other fees, a copy of that contract shall be given to the state deputy boiler inspector upon the initial inspection of the unit.